Township of Southgate

185667 Grey County Road 9, Dundalk, ON NOC 1B0

Jim Ellis,

Public Works Manager / Risk Management Official

jellis@southgate.ca

Public Works Department

Date: December 21, 2020,

File No.: SP13-20

Can a safe access be provided? Yes ☒ No □

Road Drainage Concern: None

Road Standard: Arterial/Collector

Road Widening Necessary? Yes □ No 区

Entrance Requirements: Commercial Entrance required - paved apron required

Phone: 519-923-2110 ext. 250

Toll Free: 1-888-560-6607

Fax: 519-923-9262

Cell: 519-378-3777

when Eco Parkway is paved

Load Restricted Road:

Yes □ No 🗵

Comments:

Required to be on municipal water and sanitary sewer connections.

Wastewater effluent directed to the municipal sanitary sewer system must not exceed Southgate By-law No. 13-2011 Schedule "B" Restricted Wastes Sanitary and Combined Sewer Discharges concentration limits.

It is noted in the Report that the municipal fire flows projected will not be met with the Dundalk Water Supply and the Report comments on an onsite ground water well supply for fire servicing.

Haul Route to be off of, when constructed Highway 10 access road for north, east and south bound traffic.

Southgate Anerobic Digester Public Liaison Committee to consist of one member of Southgate Council.

Risk Management Office

Property is located in a Well Head Protection Are	:a
---------------------------------------------------	----

	١	N	н	D	Δ	."A	"
1 1	٠,	/ V	ı	\mathbf{r}	М		

□ WHPA "B"

□ WHPA "C"

☑ WHPA "D"

Not Applicable

Comments:	
Northernly portion of lands in Grand River Conservation Authority (GRCA)	
watershed, WHPA "D"	

Well Head Protection Area "D" - Applicable to Dense Non- Aqueous Phase Liquid (DNAPL's) products managed by education and outreach programs.

Signed:______

Jim Ellis//Public Works Manager / Risk Management Official