

Township of Southgate

185667 Grey County Road 9,
Dundalk, ON N0C 1B0

Jim Ellis,

Public Works Manager / Risk Management Official

jellis@southgate.ca



Phone: 519-923-2110 ext. 250

Toll Free: 1-888-560-6607

Fax: 519-923-9262

Cell: 519-378-3777

Public Works Department

Date: January 7, 2021

File No.: SP15-20

Can a safe access be provided? Yes No

Road Drainage Concern: None

Road Standard: Urban Design

Road Widening Necessary? Yes No

Entrance Requirements: None

Load Restricted Road: Yes No

Comments:

Required to be on municipal water and sanitary sewer and storm water service connections. Township Engineer to confirm watermain sizing with the Dundalk Water Distribution Model.

Premise backflow prevention required on commercial buildings.

Risk Management Office

Property is located in a Well Head Protection Area:

- WHPA "A"
- WHPA "B"
- WHPA "C"
- WHPA "D"
- Not Applicable

Comments:

South-easterly corner of Lot 234 small portion of lands outside WHPA "D" in Grand River Conservation Authority (GRCA) watershed.

Well Head Protection Area "D" - Applicable to Dense Non- Aqueous Phase Liquid (DNAPL's) products managed by education and outreach programs.

Signed: _____

Jim Ellis, Public Works Manager / Risk Management Official