Township of Southgate

185667 Grey County Road 9,

Dundalk, ON NOC 1B0 Jim Ellis,

Signed:

Public Works Manager / Risk Management Official

jellis@southgate.ca				
Public Works Department				
Date: January 29, 2024				
File No.: 221 Doyle St				
Can a safe access be provided? Yes ⊠ No □				
Road Drainage Concern: None				
Road Standard: Urban asphalt				
Road Widening Necessary?		Yes □ No ⊠		
Entrance Requirements: Residential Entrances required, curb cuts & repair.				
Load Re	estricted Road:	Yes ⊠	No □	
Comme	nts:			
Splitting of water & sewer services may have to be altered or hook up to mains installed at developer's costs to meet their needs of lot adjustments.				
Complete width of asphalt to be restored for servicing excavation at Developer's cost on Artemesia & Doyle Streets				
Servicing design to be peer review by Triton Engineering				
Risk Management Office				
Property is located in a Well Head Protection Area:				
□ V	VHPA "A"			
□ V	VHPA "B"			
□ V	VHPA "C"			
× V	VHPA "D"			
- N	lot Applicable			
Comments:				
	ad Protection Area "D" - 's) products managed by			

Phone: 519-923-2110 ext. 250

Toll Free: 1-888-560-6607

Fax: 519-923-9262

Cell: 519-378-3777

Jim Ellis, Public Works Manager / Risk Management Official