Dundalk Fire Department 85 Dundalk St, Box 765 Dundalk ON NOC 1B0



Phone: (519) 923-2402 E-mail: <u>firechief@southgate.ca</u> Web: <u>www.southgate.ca</u>

Fire Department Planning Comments

Date: 2024-08-07

| File No.: C21-24 |
|---|
| Adequate water for fire suppression: |
| |
| ☐ Existing water may be adequate (pond, stream, water reservoir.) |
| ☐ Within a hydranted area or close proximity. |
| ☐ Other/Not Required |
| Comments: A water reservoir is required for this property. This water reservoir is being used to satisfy requirements for another property within the area. |
| Suppression equipment considerations: |
| ☑ Department has all equipment needed to respond. |
| \square Building would require an aerial device to respond. |
| ☐ Department will need to purchase equipment. Equipment needed: N/A |
| Other: |
| ☑ No further comments. |
| \square More information required. |
| Comments: N/A |
| Derek Malynyk |
| Southgate Fire Chief, Chief Fire Official |