



## Township of Southgate

# Dundalk Wastewater Treatment Plant

## 2024 Annual Report

### 9.7.2 PW2025-006 Dundalk Wastewater 2024 Annual Report

No. 2025-103

**Moved By** Councillor Ferguson

**Seconded By** Councillor Shipston

**Be it resolved that** Staff Report PW2025-006 be received for information; and

**That;** Council approve the Dundalk Wastewater Treatment Plant 2024 Annual Report.

Carried

**Cory Henry**  
Supervisor Water and Roads

# Dundalk Wastewater Treatment Plant 2024 Annual Report

## Table of Contents

Wastewater Treatment Plant Annual Overview.....	1
2024 General Wastewater Information.....	6
Loading Report.....	7
Performance Report.....	8
Final Effluent Discharge Report.....	9
Raw Sewage Parameters and Lab Results.....	10
Final Effluent Parameters and Lab Results.....	11

**Overview:**

The Dundalk Wastewater Treatment Plant (WWTP) provided treatment in 2024 with an annual average influent daily flow of 1,419 m<sup>3</sup>/day, a 15.12% increase over the 2023 average influent daily flow of 1,237 m<sup>3</sup>/day.

**Project Description:**

The Dundalk WWTP is a four-cell waste stabilization pond facility flowing into an aeration cell pond with a chemical feed system and a flocculation tank with tertiary treatment consisting of sand filters.

**Plant Facts:**

**Facilities:** Waste Stabilization Ponds with Tertiary Treatment

**Design Capacity:** 1832 m<sup>3</sup>/day

**Receiver Water:** Foley Drain/Grand River

**Environmental Compliance**

**Approval:** 5657-9D9LYE

**Effluent Requirements:**

Effluent Parameter	Ideal	Maximum	Maximum
	Concentration Objective	Monthly Average Concentration (MAC)	Monthly Average Loading
COBDS	5.0 mg/L	10.0 mg/L	18.32 kg/day
Total Suspended Solids (TSS)	5.0 mg/L	10.0 mg/L	18.32 kg/day
Total Phosphorous	0.30 mg/L + 5 degrees Celsius stream temperature 0.60 mg/L - 5 degrees Celsius stream temperature	0.40 mg/L + 5 degrees Celsius stream temperature 0.80 mg/L - 5 degrees Celsius stream temperature	0.73 kg/L + 5 degrees Celsius stream temperature 1.47 kg/L - 5 degrees Celsius stream temperature
Dissolved Oxygen	5.0 mg/L	4.0 mg/L	
Unionized Ammonia	0.05 mg/L	0.1 mg/L	
pH	6.5 to 8.5 at all times	6.0 to 9.5 at all times	

**Sampling Requirements:**

Sampling Criteria for this system is in accordance with Ministry Policy for the Environmental Compliance Approval (ECA) No. 5657-9D9LYE

**Final Effluent:**

A grab sample is taken twice a month and tested for CBOD, Suspended Solids, Total Phosphorus, Total Ammonia Nitrogen, Ecoli, pH and temperature.

On site testing is performed twice a week on final effluent for Total Ammonia to determine Unionized Ammonia through lab testing, pH, temperature, and Dissolved Oxygen.

**Raw Sewage:**

A grab sample is taken monthly and tested for BOD, Suspended Solids, Total Kjeldahl Nitrogen and Total Phosphorus.

**Effluent Flows:**

The total effluent flow treated in 2024 was 498,096 m<sup>3</sup>. The annual average daily flow was 1,727 m<sup>3</sup>/day, which results in a 29.49% increase of total effluent over 2023.

**Raw Sewage Quality:**

- Annual average raw sewage BOD concentration to the lagoon system was 154.3 mg/l.
- Annual average raw sewage suspended solids (TSS) concentration to the lagoon system was 271.4 mg/l.
- Annual average raw total phosphorus was 4.64 mg/l concentration to the lagoon system.
- Annual average Total Kjeldahl Nitrogen (TKN) concentration was 54.1 mg/l.

**Plant Performance and Effluent Quality:**

- Annual average effluent CBOD concentration was 3.2 mg/l.
- Annual average effluent total suspended solids (TSS) concentration was 5.67 mg/l day with a removal efficiency of 97.24% with an annual monthly average loading of 11.3 kg/day.
- Annual average effluent total phosphorus concentration was 0.05 mg/l day with a removal efficiency of 98.65% with an annual monthly average loading of 0.10 kg/day.
- Annual average effluent concentration for Ammonia-nitrogen was 5.20 mg/l.
- Annual average Unionized Ammonia was 0.063026 mg/l.
- Annual average pH was 8.00.
- Annual monthly average Ecoli was 38 with the low being 2 and the high being 160.
- The summary for 2024 of the data for the systems plant operation performance is enclosed in this report.

## **Maintenance and Calibration Activities:**

Regular monthly preventative maintenance and calibration of test equipment and flow meters are performed by municipal staff and outside certified suppliers.

Third party annual calibrations were performed on October 30, 2024.

**There was 1 by-pass event to report** – By-pass event occurred for Cells 1 & 4 from April 19<sup>th</sup> to 26<sup>th</sup>, 2024. Additionally, there was a MECP approved emergency discharge event due to lagoon cell capacities beginning April 12 and ending on May 29, 2024.

Details of these events are as follows:

An Emergency Discharge Event (EDE), through the filters, was initiated on April 12, 2024, prompted by alarmingly high-water levels across all Lagoon Cells, coupled with an inability to discharge due to effluent not meeting prescribed limits stipulated in the ECA for: Un-ionized ammonia (UIA), limit of 0.1 mg/L and Total Suspended Solids (TSS) limit of 10 mg/L.

Observations on April 18 at 11:30am, revealed an overflow of raw sewage from the Cell 1 inlet structure.

To reduce/eliminate this overflow and mitigate the risks of berm breaching or structural compromise on the lagoons, discharge from Cell 4 commenced on April 19.

By April 23, the spill had stopped, with an estimated spill volume of 1,294m<sup>3</sup>.

Persistently high-water levels justified the continued discharge from Cell 4 until April 26 in an estimated total volume of 23,949m<sup>3</sup>, bypassing Cell 5 and the filtration system.

In the beginning of May, consultations with OCWA, GRCA and WaterIQ Technologies yielded the idea of deploying an ultrasonic device in Cell 4 to mitigate algae growth, thereby modulation pH, implemented on May 3.

Concurrently, a subsequent application of alum in Cells 3 and 4 demonstrated promising results, with effluent parameter showing favorable trend towards compliance.

Upon ending the EDE, normal operations resumed at the Dundalk WWTF, with effluent parameters consistently meeting the ECA requirements.

The EDE concluded on May 29, due to concerns regarding reduced effluent receiver flows and higher ambient temperatures.

Duration of EDE: 41 days

A total volume of 144,456m<sup>3</sup> was discharged, inclusive of the 23,949m<sup>3</sup> from Cell 4.

The Township and Triton Engineering have developed a mitigation plan including enhanced monitoring and reporting to the MECP.

## There were 6 operator shutdowns in 2024.

Please reference below table for shutdowns and limit exceedances for 2024.

### 2024 Wastewater effluent parameters compliance exceedances and shutdowns

	Monthly Average Effluent Concentration					Monthly Average Effluent Loading (kg/d)			Lagoon Shutdown Duration	Comments
	COBDS	TSS	TP	Unionized Ammonia	pH	COBDS	TSS	TP		
	Limit	Limit	Limit	Limit	Limit	Limit	Limit	Limit		
	10.0 mg/day	10.0 mg/L	0.4 mg/L - > 5 C 0.8 mg/L - < 5 C	0.05 mg/L = daily testing 0.13 mg/L = proactive shutdown 0.15 mg/L = shutdown	< 6.0 or > 9.5	18.32 kg/day	18.32 kg/day	0.4 kg/L - > 5 C 0.8 kg/L - < 5 C		
JAN				0.056			21.3		27	4 days over 0.05mg/L UIA 23 days over 10mg/L TSS 4 days TSS Loading
FEB				0.07			17.6		23	9 days over 10mg/L TSS 7 days <0.1mg/L UIA 7 days >0.1 mg/L UIA
MAR				0.142			21.8		30	14 days over 0.1mg/L 1 days TSS loading
APR				0.185			16.3		7	2 days over 0.15mg/L 5 days over 0.15mg/L
MAY				0.171						15 days over 0.15mg/L
JUN										
JUL										
AUG										
SEP										
OCT										
NOV										
DEC										

Note: If daily testing for unionized ammonia occurs on a Friday we shut down for the weekend.

  - Shutdown due to exceedance.

  - Shutdown as a proactive measure due to approaching an exceedance.

Note: April 12, 2025, MECP approval to emergency discharge due to zero capacity. Emergency discharge ended May 29, 2025.

Note: MECP inspector interpretation of C of A, unionized ammonia limit, allows discharge of effluent with <0.15mg/L.

There were loading exceedances in January and March for effluent suspended solids. We discharged for 4 days in January and 1 day in March.

### Discussion:

The Dundalk Wastewater Treatment upgrades are awaiting Ministry approval of the ECA amendment for the Dundalk Sewage Works.

Upon issuance of the ECA amendment, Triton Engineering will release the tender documents, followed by award of the contract by Southgate Council. Construction is anticipated for 2025 for the first phase of the upgrades.

Installation of a new influent sewage pumping station to manage increased flow effectively. Additionally, enhancements such as incorporation of additional aeration and a floating cover in the final cell of the lagoons, will aid in algae removal, thus improving overall treatment efficiency.

A major component of this project is the construction of a 22m x 5.5m concrete tank utilizing advanced Moving Bed Biofilm Reactor (MBBR) technology, which will optimize ammonia reduction.

Upgrading the tertiary media filter to a state-of-the-art disk filter system will ensure effective removal of Total Suspended Solids.

Finally, implementing a new Ultraviolet (UV) disinfection system will play a critical role in reducing E.coli levels, thereby enhancing the quality of treated wastewater.

This expansion is expected to increase the treatment capacity of the facility by over 65% from 1832m<sup>3</sup>/day to 3025m<sup>3</sup>/day.

The Township of Southgate received from the MECP a Consolidated Linear Infrastructure – Environmental Compliance Approval (CLI-ECA) for the Municipal Sewage Collection System, ECA Number 110-W601, issued March 2, 2023.

**Township of Southgate - Village of Dundalk**

2024 General Wastewater Information

Plant # : 0-101006-67

ECA # : 5657-9D9LYE

Population: 2,803 (Village of Dundalk)

**Flows**

	<u>Design</u>		<u>2024</u>	<u>2023</u>	<u>2022</u>	<u>2021</u>	<u>2020</u>	<u>2019</u>	<u>2018</u>	<u>2017</u>
Capacity:	208,500									
Influent Average Daily:	-	m <sub>3</sub>	1,419	1,237	990	1,220	1,161	1,114	1,105	1,168
Annual Influent Flow:	668,600	m <sub>3</sub>	518,945	450,793	360,770	446,719	425,922	405,664	401,279	424,727
Influent Maximum Daily:	-	m <sub>3</sub>	5,736	4,017	3,247	6,740	4,510	3,989	9,022	6,362
Effluent Average Daily (days operating):	1,832	m <sub>3</sub>	1,785	1,497	1,196	2,096	1,087	1,315	1,355	1,230
Annual Effluent Flow:	-	m <sub>3</sub>	498,096	384,666	312,215	470,150	396,688	407,659	404,853	420,598
% Discharge vs. Total Capacity:	-		74.5%	57.5%	46.7%	70.3%	59.3%	61.0%	60.6%	62.9%
Influent Increase 2024 over 2023:	-		15.12%	24.95%	-19.24%	4.88%	4.99%	1.09%	-5.52%	17.94%
Effluent Increase 2024 over 2023:	-		29.49%	23.21%	-33.59%	18.52%	-2.69%	0.69%	-3.74%	25.67%



**Township of Southgate**  
**Loading Report - Dundalk Wastewater Plant**

Municipality: Township of Southgate Year: 2024  
 Plant: Dundalk Wastewater Treatment Lagoons & Collection System  
 Plant #: 0-101006-67  
 Works #: 110001471  
 System Description: Faculative Lagoons & Sand Filters

Month	Loading Influent			Effluent Loading		
	BOD kg/day	SS kg/day	T Phos. kg/day	Effluent CBOD kg/day	Effluent SS kg/day	Effluent T Phos. kg/day
January	206.6	342.7	6.0	8.5	21.3	0.17
February	197.1	320.5	5.5	8.8	17.6	0.20
March	293.3	276.9	7.6	7.6	21.8	0.23
April	324.0	628.0	7.5	8.2	16.3	0.22
May	281.8	384.2	7.4	7.7	9.2	0.05
June	211.3	469.6	4.6	7.2	8.4	0.05
July	183.5	377.7	5.7	5.9	5.9	0.06
August	133.8	248.7	5.6	5.8	7.7	0.06
September	140.3	244.0	5.3	4.5	5.9	0.04
October	177.2	340.9	5.5	3.0	7.5	0.07
November	177.4	371.7	6.6	2.5	5.5	0.03
December	196.6	273.5	5.7	4.4	8.0	0.04
Total	2522.7	4278.4	72.8	74.1	135.3	1.22
Average	210.2	356.5	6.1	6.2	11.3	0.10
Maximum	324.0	628.0	7.6	8.8	21.8	0.23

PS = Plant Shutdown

= loading exceedance

**Township of Southgate  
Performance Report - Dundalk Wastewater Plant**

Municipality: Township of Southgate  
 Plant: Dundalk Wastewater Treatment Lagoons & Collection System  
 Plant #: 0-101006-67  
 Works #: 110001471  
 System Description: Faculative Lagoons & Sand Filters

Year: 2024  
 Receiver: Foley Drain - Grand River  
 Design Average Day Flow (m3): 1832

Month	Flows			Effluent Total Flow m3	Discharge Duration Days	Bio-Chemical Oxygen Demand			Suspended Solids			Phosphorus			E Coli average Effluent Count	Temperature < 5 C. or > 5 C.	TKN mg/l	Nitrogen Series			Effluent CBOD kg/day	Effluent SS kg/day	Effluent T Phos. kg/day
	Total Flow m3	Avg. Flow m3	Max. Flow m3			Avg. Raw BOD mg/l	Avg Effluent CBOD mg/l	Percent Removal	Avg. Raw SS mg/l	Avg. Effluent SS mg/l	Percent Removal	Avg. Raw T. Phos mg/l	Avg. Effluent T. Phos mg/l	Percent Removal				Avg. Effluent NH3 + NH4 mg/l	Unionized Ammonia mg/l				
January	47422	1530.00	2400.00	8523	4	135.0	4.0	97.04%	224.0	10.0	95.54%	3.90	0.08	97.95%	90	2.5	40.5	9.84	0.056067	8.5	21.3	0.2	
February	49695	1714.00	2952.00	12545	5.7	115.0	4.0	96.52%	187.0	8.0	95.72%	3.20	0.09	97.19%	5	3.2	30.1	10.84	0.070844	8.8	17.6	0.2	
March	63590	2051.0	2557.0	1894	1	143.0	4.0	97.2%	135.0	11.5	91.5%	3.7	P/S	96.8%	43	4.9	38.5	14.75	0.142809	7.6	21.8	0.2	
April	74745	2492.00	5736.00	55963	23.3	130.0	3.4	97.38%	252.0	6.8	97.30%	3.00	0.09	97.00%	54	7.8	33.9	13.42	0.185293	8.2	16.3	0.2	
May	49617	1601.00	3018.00	79545	31	176.0	3.0	98.30%	240.0	3.6	98.50%	4.60	0.02	99.57%	8	16.6	43.3	9.21	0.171087	7.7	9.2	0.1	
June	35214	1174.00	1636.00	72384	30	180.0	3.0	98.33%	400.0	3.5	99.13%	3.90	0.02	99.49%	79	20.3	61.2	2.06	0.051982	7.2	8.4	0.0	
July	33252	1073.00	2284.00	61351	31	171.0	3.0	98.25%	352.0	3.0	99.15%	5.30	0.03	99.43%	9	23.0	70.0	0.61	0.004138	5.9	5.9	0.1	
August	32408	1045.00	1553.00	59878	31	128.0	3.0	97.66%	238.0	4.0	98.32%	5.40	0.03	99.44%	4	21.5	56.4	0.43	0.002573	5.8	7.7	0.1	
September	25505	850.00	1025.00	44535	30	165.0	3.0	98.18%	287.0	4.0	98.61%	6.20	0.03	99.52%	2	18.9	78.7	0.05	0.001687	4.5	5.9	0.0	
October	24853	802.00	949.00	31111	31	221.0	3.0	98.64%	425.0	7.5	98.24%	6.80	0.07	98.97%	4	11.6	87.4	0.80	0.012730	3.0	7.5	0.1	
November	31866	1062.00	1403.00	25216	30	167.0	3.0	98.20%	350.0	6.5	98.14%	6.20	0.04	99.35%	2	5.9	74.7	3.6	0.027533	2.5	5.5	0.0	
December	50778	1638.00	3615.00	45151	31	120.0	3.0	97.50%	167.0	5.5	96.71%	3.50	0.03	99.14%	160	1.0	35.3	6.33	0.029574	4.4	8.0	0.0	
Total	518945			498096	279.0																		
Average	43245	1419		41508		154.3	3.3	97.77%	271.4	6.2	97.24%	4.64	0.05	98.65%	38	11.4	54.1	6.00	0.063026	6.2	11.3	0.1	
Maximum	74745	2492	5736	79545		221.0	4.0		425.0	11.5		6.80	0.09		160	23.0	87.4	14.75	0.185293	8.8	21.8	0.2	

PS = Plant Shutdown

**Township of Southgate**  
**Annual Report - Dundalk Wastewater Plant**

Plant: Dundalk Wastewater Treatment Lagoons & Collection System  
 Works: 110001471  
 Year: 2024  
 Location Type: **Final Effluent Discharge Report**

Month	Discharge Duration Days	Total Effluent m3	Total Coagulant Used (kg)	Average Coagulant Dosage (mg/l)	Average CBOD mg/l	Average SS mg/l	Average T. Phos. mg/l	Average NH <sub>3</sub> + NH <sub>4</sub> as N (mg/l)	E Coli average Count	Average pH Reports	Average Temp. C	Average D.O. mg/l
January	4	8523	0.20	15.3	4.0	10.0	0.08	9.84	90	8.01	2.50	10.17
February	5.7	12545	0.29	14.8	4.0	8.0	0.09	10.84	5	8.01	3.20	9.53
March	1	1894	0.05	17.2	4.0	11.5	0.12	14.75	43	8.07	4.90	8.63
April	23.3	55963	1.17	13.5	3.4	6.8	0.09	13.42	54	8.08	7.80	10.30
May	31	79545	1.55	12.7	3.0	3.6	0.02	9.21	8	8.12	16.60	7.79
June	30	72384	1.50	13.5	3.0	3.5	0.02	2.06	79	7.88	20.30	7.02
July	31	61351	1.55	16.4	3.0	3.0	0.03	0.61	9	7.72	23.00	7.26
August	31	59878	1.55	16.8	3.0	4.0	0.03	0.43	4	8.06	21.50	7.40
September	30	44535	1.50	21.9	3.0	4.0	0.03	0.05	2	8.05	18.90	7.34
October	31	31111	1.55	32.4	3.0	7.5	0.07	0.80	4	8.02	11.60	8.80
November	30	25216	1.50	38.7	3.0	6.5	0.04	3.61	2	8.05	5.90	10.55
December	31	45151	1.55	22.3	3.0	5.5	0.03	6.33	160	8.04	1.00	12.69
Total	279	498096	13.95									
Average		45109	1.26	19.84	3.22	5.67	0.05	5.20	38	8.00	12.03	8.99
Maximum		79545			4	11.5	0.12	14.75	160	8.12	23.00	12.69

PS = Plant Shutdown

**Township of Southgate - Village of Dundalk**  
**Annual Report - Dundalk Wastewater Plant**

**Plant:** Dundalk Wastewater Treatment Lagoons & Collection System  
**Works:** 110001471  
**Classification:** Class 1 Wastewater Collection & Class 1 Wastewater Treatment  
**Receiver:** Foley Drain to Grand River

**Year:** 2024  
**Population Served:** 2803

Raw Sewage Parameters		January	February	March	April	May	June	July	August	September	October	November	December	Summary
	Average	135	116	143	136	223	180	171	123	165	220	167	120	158
<b>BOD</b>	Minimum	129	113	140	106	98	138	136	95	148	186	160	73	127
	Maximum	140	118	145	165	348	222	205	150	182	254	174	167	189
<b>Suspended</b>	Average	224	187	135	336	255	400	353	250	288	425	350	168	281
<b>Solids</b>	Minimum	158	186	124	122	164	250	235	170	280	415	330	110	212
	Maximum	290	188	146	550	345	550	470	330	295	435	370	225	350
	Average	40.5	30.1	38.5	37.9	40.1	61.2	70.0	47.5	78.7	87.4	74.7	35.3	53.5
<b>TKN</b>	Minimum	38.6	29.4	24.2	26.9	20.5	50.1	51.6	43.2	59.1	82.1	47.4	20.3	41.1
	Maximum	42.4	30.7	52.7	48.9	59.7	72.2	88.4	51.7	98.3	92.7	102.0	50.2	65.8
<b>Total</b>	Average	3.87	3.28	3.68	2.51	4.16	3.88	5.25	5.48	6.27	6.79	6.29	3.46	4.57
<b>Phosphorus</b>	Minimum	3.75	3.12	1.94	0.77	2.47	1.61	3.70	4.23	5.94	5.91	4.31	2.12	3.32
	Maximum	3.98	3.44	5.41	4.25	5.85	6.14	6.80	6.73	6.59	7.67	8.27	4.79	5.83

PS = Plant Shutdown

**Township of Southgate - Village of Dundalk**  
**Annual Report - Dundalk Wastewater Plant**

**Plant:** Dundalk Wastewater Treatment Lagoons & Collection System  
**Works:** 110001471  
**Classification:** Class 1 Wastewater Collection & Class 1 Wastewater Treatment  
**Receiver:** Foley Drain to Grand River

**Year:** 2024  
**Population Served:** 2803

Final Effluent Parameters		January	February	March	April	May	June	July	August	September	October	November	December	Summary
	Average	4.0	4.0	4.0	3.5	3.0	3.0	3.0	3.5	3.0	3.0	3.0	3.0	3.3
<b>CBOD</b> <b>mg/l</b>	Minimum	4.0	3.0	3	3	3.0	3.0	3	3.0	3.0	3.0	3.0	3.0	3.0
	Maximum	4.0	5.0	5	4	3.0	3.0	3	4.0	3.0	3.0	3.0	3.0	5.0
<b>Suspended Solids</b> <b>mg/l</b>	Average	8.5	8.0	11.5	7.0	4.5	3.5	3.0	4.0	4.0	7.5	6.5	5.5	6.1
	Minimum	3.0	6.0	11	3	3.0	3.0	3	3.0	3.0	5.0	3.0	3.0	3.0
	Maximum	14.0	10.0	12	11	6.0	4.0	3	5.0	5.0	10.0	10.0	8.0	14.0
	Average	9.4	10.8	14.8	13.4	9.0	2.1	0.6	0.5	0.1	0.8	3.6	6.3	5.95
<b>NH3 + NH4</b> <b>mg/l</b>	Minimum	7.54	6.88	14	12.5	5.75	0.40	0.37	0.11	0.05	0.47	3.03	4.89	0.05
	Maximum	11.30	14.80	15.5	14.2	12.30	3.71	0.85	0.90	0.05	1.13	4.19	7.78	15.50
	Average	11.85	12.95	19.00	16.50	9.45	2.60	1.50	1.85	1.15	2.65	5.00	9.15	7.80
<b>TKN</b> <b>mg/l</b>	Minimum	11.10	7.90	17.9	12.4	5.60	1.10	1.3	1.40	1.10	2.20	4.70	7.50	1.10
	Maximum	12.60	18.00	20.1	20.6	13.30	4.10	1.7	2.30	1.20	3.10	5.30	10.80	20.60
<b>Total Phosphorus</b> <b>mg/l</b>	Average	0.09	0.10	0.13	0.11	0.02	0.02	0.03	0.04	0.03	0.07	0.04	0.03	0.06
	Minimum	0.06	0.07	0.11	0.04	0.01	0.02	0.02	0.03	0.03	0.06	0.03	0.02	0.01
	Maximum	0.11	0.12	0.14	0.17	0.03	0.02	0.03	0.04	0.03	0.07	0.04	0.04	0.17
	Average	133.00	5.00	43.00	69.00	12.00	79.00	9.00	4.50	2.00	4.00	2.00	160.00	44
<b>Ecoli</b>	Minimum	2	4	2	2	2	2	2	3	2	2	2	2	2
	Maximum	264	6	84	136	22	156	16	6	2	6	2	318	318
<b>pH Lab Results</b> <b>(In-house testing not included)</b>	Average	8.05	8.01	8.07	8.08	8.16	7.88	7.72	8.08	8.05	8.03	8.05	8.04	8.02
	Minimum	8.01	7.96	8.03	8.02	8.02	7.79	7.45	7.99	8.04	8.00	8.00	7.92	7.45
	Maximum	8.08	8.05	8.1	8.13	8.29	7.97	7.98	8.16	8.06	8.06	8.09	8.16	8.29
	Average	11.55	9.80	8.85	10.10	7.80	7.05	7.20	7.30	7.10	8.55	10.15	10.75	8.85
<b>DO</b> <b>mg/l</b>	Minimum	9.10	5.80	6	8.8	6.90	6.00	5.8	6.00	5.50	5.80	7.20	7.59	5.50
	Maximum	14.00	13.80	11.7	11.4	8.70	8.10	8.6	8.60	8.70	11.30	13.10	13.90	14.00
<b>Unionized Ammonia</b> <b>mg/l</b>	Average	0.076550	0.088350	0.148300	0.218650	0.235040	0.054700	0.004730	0.002650	0.002380	0.017740	0.034000	0.025185	0.075690
	Minimum	0.040300	0.030000	0.016600	0.088900	0.045380	0.002300	0.000860	0.000500	0.000059	0.000080	0.013100	0.006900	0.000059
	Maximum	0.112800	0.146700	0.280000	0.348400	0.424700	0.107100	0.008600	0.004800	0.004700	0.035400	0.054900	0.043470	0.424700

PS = Plant Shutdown